

## Certificate of compliance

Applicant: Huawei Technologies Co., Ltd

Administration Building

Headquarters of Huawei Technologies Co. Ltd. Bantian, Longgang District, Shenzhen, 518129

P.R. China

Product: Photovoltaic (PV) inverter

Model: SUN2000-8KTL

SUN2000-10KTL SUN2000-12KTL SUN2000-15KTL SUN2000-17KTL SUN2000-20KTL SUN2000-23KTL SUN2000-28KTL

## Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with IEC 61727:2004 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverters.

## Applied rules and standards:

NRS 097-2-1:2010 ed1.0

Grid interconnection of embedded generation Part 2: Small-scale embedded generation Section 1: Utility interface

IEC 61727:2004 ed2.0

Photovoltaic (PV) systems - Characteristics of the utility interface

IEC 62116:2008 ed1.0

Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters

**DIN V VDE V 0126-1-1:2006-02 (Functional safety)** 

Automatic disconnection device between a generator and parallel to the public low voltage network

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: PV141230N007

Certificate number: U15-0085
Date of issue: 2015-03-16

Certification body

Dieter Zitzmann

DAKKS

Deutsche
Akkreditierungsstelle
D-ZE-12024-01-01

Certification body of Bureau Veritas Consumer Products Services Germany GmbH Accredited according to EN 45011 - ISO / IEC Guide 65